

Certificate

Registration No.: PV 50196748

Page 1

Report No.: 15037606.004

License Holder:
SENERSUN LIMITED
3905 Two Exchange Square,
8 Connaught Place,
Central Hongkong

Manufacturing Plant:
0001-15037606 001

Product:
PV Module
Type:
Module type family with 6" mono cell type:
72 cells : SSM72CxxxAU1-A (xxx=255-300 in
increment of 5)
60 cells : SSM60CxxxAU1-A (xxx=210-250 in
increment of 5)
Module type family with 5" mono cell type:
72 cells : SSM72AxxxAU1-A (xxx=165-195 in
increment of 5)
Module type family with 6" poly cell type:
72 cells : SSP72CxxxAU1-A (xxx=250-290 in
increment of 5)
60 cells : SSP60CxxxAU1-A (xxx=210-240 in
increment of 5)

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety
qualification"

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Safety tested,
IEC 61730
- Periodic inspection


Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants
at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 15037660.002.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or
processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 25 July 2015.



Certification body

Dipl.-Ing. Matthias Grzam

Shanghai, 28 January 2011

TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg
Contact: + (+49) 221 806-1371 email: cert-validity@de.tuv.com